



Terra Spiritus Purgamus

**SALEMHOWES ASSOCIATES INC.**  
GEOLOGISTS AND GEOTECHNICAL ENGINEER

Oak 531 10Jul  
0002017

## GEOTECHNICAL DESIGN MEMORANDUM

10 July 2014

**TO:** Town of San Anselmo, Public Works Department, Building Division

**Copy:** Kaveh Alizadeh

**SUBJECT:** 531 Oak Avenue, San Anselmo, Alizadeh Residence, AP 007-201-12  
Geotechnical Review of Project Drawings

Kaveh Alizadeh is authorized to use our 7 June 2001 rev 1 report for his engineering design.

We have reviewed the report and site conditions and judge the conclusions and recommendations in the report are currently valid, except the seismic section should read:

"Seismic Design

For California Building Code design purposes at this site the top 100 feet of the ground has an average Soil Profile Site of Class B per section 1613.3.2. Seismic Design Site Class".

To conform to the 1213 CBC.

We have reviewed the project structural drawings by Neil O Anderson, "S" series sheets 25 April 2014 for their geotechnical content and find that the notes and drawings are in substantial compliance with our recommendations. We judge that the design of the retaining walls is appropriate for the geologic conditions at the site.

For the record we have been retained by the owner to provide construction observations to assure that the geotechnical aspect of the work is in significant conformity with our geotechnical report.



For SalemHowes Associates Inc.

  
E Vincent Howes

Geotechnical Engineer  
GE #965 Exp. 31 Mar 16

1202 GRANT AVE. SUITE F  
NOVATO, CALIFORNIA 94945  
(415) 892-8528  
FAX 892-8568  
howesgeo@aol.com